

Resistance to fire classifications

According to European Standard EN 13501-2



Classification	Test conditions	Required functions			
	Material behind the cladding	Temperature increase behind the cladding	Nothing falling down	No damage behind the cladding	Time
K1-10	Material < 300 kg/m ³	< 250 °C	x	x	10 minutes
K2-10	Chipboard	< 250 °C	x	x	10 minutes
K2-30	Chipboard	< 250 °C	x	x	30 minutes
K2-60	Chipboard	< 250 °C	x	x	60 minutes